	Water shut off sprinklers.	Generally defective equipment and unsprinklered portions.	Defective water supply or supplies.	Sprinkler system crippled due to freezing.	Slow operation of dry system or defective dry valve.	Slow or defective operation of high test heads.	Faulty building construction, concealed spaces, vertical openings.	Obstruction to distribution.	Hazard of occupancy too severe for average sprinkler equipment.	Sprinkler system crippled by explosion.	Exposure or conflagration.	Plugged heads.	Miscellaneous.	Total.
Warehouses	17	6	4	..	3	..	2	4	3	..	..	..	4	43
Waste and Batting Mills	7	4	4	2	..	1	..	2	2	..	..	..	1	23
Waste Paper and Rag Shops	7	1	1	..	..	..	..	..	..	..	..	..	2	11
Weaving Mills	1	2	2	1	..	..	..	1	..	..	..	..	..	7
Window Shade Factories	..	..	..	1	..	..	..	..	1	..	..	..	..	2
Woodworkers, Class A*	12	10	4	..	1	1	1	6	1	3	3	1	4	47
Woodworkers, Class B*	6	9	3	2	1	2	1	1	..	3	2	..	3	33
Woodworkers, Class C*	5	4	3	..	..	..	..	3	..	..	..	..	..	15
Woodworkers, Class D*	2	10	..	1	1	..	..	..	..	2	4	..	3	23
Woodworkers, Class E*	5	2	1	..	2	1	2	..	..	..	1	..	..	14
Woodworkers, Class F*	2	..	1	..	..	..	..	1	..	..	..	..	..	4
Woolen Mills	17	19	14	1	..	2	4	..	1	..	3	..	9	70
Wool Scouring Plants	..	1	1	..	..	..	1	..	..	..	..	..	..	3
Wool Storehouses	..	2	..	..	..	..	..	..	..	..	..	..	1	3
Worsted Mills	3	3	2	1	..	..	1	..	..	..	..	..	4	14
Total	602	362	171	50	53	25	93	100	114	84	79	25	131	1889

*See detailed classification of Woodworkers as given in note under Table No. 4.
†See note on Metal Workers under Table No. 4.

VOLUME XXIV. INDEX.

A	Quarterly No.	Page No.
Airplane Fire Extinguished with Carbon Dioxide	2	146
Airplane Hangars—Fire Record	1	6
Airplane Hangar Fire Tests	2	149
Airport Fire, Chicago. *Chicago Board of Underwriters*	2	158
Apartment Building Fires, Four	4	447
Automatic Sprinklers, Annual Tables	4	476
Automobile Fire Hazards	3	338
Automobile Fire Record	3	342
B		
Baltimore, Western Maryland, Railway Elevator Explosion	3	307
Bayonne Oil Terminal Fire	1	51
The Bluebell	4	377
Board of Directors Meetings: June 16, 1930	1	12
January 17, 1931	4	373
Boston Bridge Fire. *Photograph.*	1	4
Brooklyn Oil Refinery Fire	3	334
Buildings Under Construction—Fire Record	2	196
Buildings Under Construction, Two Fires in	3	330
C		
Canadian Fire Losses, 1929. *Dominion Fire Prevention Association*	1	36
Canadian National S.S. Pier Fire, Vancouver. *F. F. Dowling*	2	211
Capitol Buildings—Fire Record	4	420
Carbon Dioxide on Airplane Fire	2	146
Chattanooga, The Robert Scholze Tannery Fire. *Tennessee Inspection Bureau*	1	44
Chicago, Curtis Candy Co. Fire. *Chicago Board of Underwriters*	2	206
Chicago Municipal Airport Fire. *Chicago Board of Underwriters*	2	158
Church Fires in Ontario and Quebec	4	463
Conflagration Map of U. S., 1930	3	248
Credit Information for Fire Departments. *Editorial*	3	242
Cypremort, La., Sugar House Fire. *H. L. McLean*	3	336
D		
Decatur, Ill., Explosion at Staley Manufacturing Co. Plant	3	323
Drill Towers, Fire Department	4	403

	Water shut off sprinklers.	Generally defective equipment and unsprinklered portions.	Defective water supply or supplies.	Sprinkler system crippled due to freezing.	Slow operation of dry system or defective dry valve.	Slow or defective operation of high test heads.	Faulty building construction, concealed spaces, vertical openings.	Obstruction to distribution.	Hazard of occupancy too severe for average sprinkler equipment.	Sprinkler system crippled by explosion.	Exposure or conflagration.	Plugged heads.	Miscellaneous.	Total.
Warehouses	17	6	4	..	3	..	2	4	3	..	..	..	4	43
Waste and Batting Mills	7	4	4	2	..	1	..	2	2	..	..	..	1	23
Waste Paper and Rag Shops	7	1	1	..	..	..	..	..	..	..	..	..	2	11
Weaving Mills	1	2	2	1	..	..	..	1	..	..	..	..	..	7
Window Shade Factories	..	..	..	1	..	..	..	..	1	..	..	..	..	2
Woodworkers, Class A*	12	10	4	..	1	1	1	6	1	3	3	1	4	47
Woodworkers, Class B*	6	9	3	2	1	2	1	1	..	3	2	..	3	33
Woodworkers, Class C*	5	4	3	..	..	..	..	3	..	..	..	..	..	15
Woodworkers, Class D*	2	10	..	1	1	..	..	..	..	2	4	..	3	23
Woodworkers, Class E*	5	2	1	..	2	1	2	..	..	..	1	..	..	14
Woodworkers, Class F*	2	..	1	..	..	..	..	1	..	..	..	..	..	4
Woolen Mills	17	19	14	1	..	2	4	..	1	..	3	..	9	70
Wool Scouring Plants	..	1	1	..	..	..	1	..	..	..	..	..	..	3
Wool Storehouses	..	2	..	..	..	..	..	..	..	..	..	..	1	3
Worsted Mills	3	3	2	1	..	..	1	..	..	..	..	..	4	14
Total	602	362	171	50	53	25	93	100	114	84	79	25	131	1889

*See detailed classification of Woodworkers as given in note under Table No. 4.
†See note on Metal Workers under Table No. 4.

VOLUME XXIV. INDEX.

A	Quarterly No.	Page No.
Airplane Fire Extinguished with Carbon Dioxide	2	146
Airplane Hangars—Fire Record	1	6
Airplane Hangar Fire Tests	2	149
Airport Fire, Chicago. *Chicago Board of Underwriters*	2	158
Apartment Building Fires, Four	4	447
Automatic Sprinklers, Annual Tables	4	476
Automobile Fire Hazards	3	338
Automobile Fire Record	3	342
B		
Baltimore, Western Maryland, Railway Elevator Explosion	3	307
Bayonne Oil Terminal Fire	1	51
The Bluebell	4	377
Board of Directors Meetings: June 16, 1930	1	12
January 17, 1931	4	373
Boston Bridge Fire. *Photograph.*	1	4
Brooklyn Oil Refinery Fire	3	334
Buildings Under Construction—Fire Record	2	196
Buildings Under Construction, Two Fires in	3	330
C		
Canadian Fire Losses, 1929. *Dominion Fire Prevention Association*	1	36
Canadian National S.S. Pier Fire, Vancouver. *F. F. Dowling*	2	211
Capitol Buildings—Fire Record	4	420
Carbon Dioxide on Airplane Fire	2	146
Chattanooga, The Robert Scholze Tannery Fire. *Tennessee Inspection Bureau*	1	44
Chicago, Curtis Candy Co. Fire. *Chicago Board of Underwriters*	2	206
Chicago Municipal Airport Fire. *Chicago Board of Underwriters*	2	158
Church Fires in Ontario and Quebec	4	463
Conflagration Map of U. S., 1930	3	248
Credit Information for Fire Departments. *Editorial*	3	242
Cypremort, La., Sugar House Fire. *H. L. McLean*	3	336
D		
Decatur, Ill., Explosion at Staley Manufacturing Co. Plant	3	323
Drill Towers, Fire Department	4	403

	Quarterly No.	Page No.
Drought and the Fire Loss. *Editorial*	2	120
Drought Regions, Water Supplies in	4	382
Dust Explosions—Review of Recent. *David J. Price and H. R. Brown*	3	305
—Western Maryland Elevator, Baltimore	3	307
—Hogan Mill Feed Plant, Kansas City, Mo.	3	313
—E. F. Carlston Elevator, Minneapolis	3	318
—Tobacco By-Products and Chemical Plant, Richmond, Va.	3	320
—Staley Manufacturing Co., Decatur, Ill.	3	323
Dwelling House Inspection, Providence	3	251

E

Earthquakes and Fire. *Editorial*	4	371
Earthquake and Fire, New Zealand	4	387
Eden Square Apartments Fire, Stockton, Cal. *Stockton Fire Fighters Relief Association*	4	451
Empire State Building Fire, New York City	3	333
Executive Committee Meeting, May 12, 1930	1	12

F

Fairfax Disaster. *Editorial*	1	8
Federal Trade Commission Building Fire, Washington, D. C.	2	123
Fire Department Drill Towers	4	403
Fire Chiefs to the Rescue. *Editorial*	3	240
Fire Effects on Fire-Resistive Construction. *Frank Burton*	3	277
Fire Losses, Annual Conflagration Map, U. S.	3	248
Fire Losses, Canadian, 1929. *Dominion Fire Prevention Association*	1	36
Fire Losses, Comparative	1	38
Fire Losses, Great Britain and Ireland, 1929	1	37
Fire Losses, U. S. 1929. *National Board of Fire Underwriters*	1	31
Fire Losses, U. S., 1929 and 1930. *National Board of Fire Underwriters*	4	380
Fire Losses, U. S., 1930. *National Board of Fire Underwriters*	3	247
Fire Loss Trend. *Editorial*	2	118
Firemen's Short Extension Courses. *Clarence Goldsmith*	3	286
Fireproofing of Fabrics	2	184
Fire Record—Airplane Hangars	1	6
—Automobiles	3	342
—Buildings Under Construction	2	196
—Capitol Buildings	4	420
—Paint and Lacquer Spraying	2	131
—Theatres	1	55
Fire Temperatures and Building Construction. *Frank Burton*	2	163
Fireworks in New Jersey	2	127

G

Gas Overcomes Rochester Firemen	4	467
Generous Minneapolis. *Editorial*	4	369
Great Britain and Ireland, Fire Losses	1	37

H

Hangar Fire Tests	2	149
Harrisburg, Pa., State Education Building	3	330
High Tension Wires and Hose Streams. *H. S. Walker*	2	169
Horse Show Fire, Oakland, Cal. *Clarence Heller*	4	444

I

Incorporation of the N.F.P.A. *Edward R. Hardy*	1	17

K

Kansas City, Mo., Hogan Mill Feed Company Plant Explosion	3	313

L

Lincoln Square Arcade Building Fire, New York. *New York Board of Fire Underwriters*	4	448
Locating Leaks in Underground Yard Mains	2	140
Loss of Life Fires	1	109
	2	231
	3	358
	4	472
Loss of Life in Mine Fires. *Editorial*	2	121
Loss of Life in Sprinklered Fires	2	218
Lynn, Mass., Hotel Lenox Fire	4	458

M

Measuring Fire Protection Benefits in Dollars. *Clyde M. Wood*	3	245
Miniature Golf Courses. *Gorham Dana*	2	122
Minneapolis, Explosion at E. F. Carlston Elevator	3	318
Minneapolis, Generous. *Editorial*	4	369
Municipal Regulation of Oil Storage. *Robert S. Moulton*	3	255

N

New Jersey, Fireworks Legislation	2	126
Newspaper Fire Stories. *Editorial*	3	243
New York City, Empire State Building Fire	3	333

	Quarterly No.	Page No.
New York City, Lincoln Square Arcade Building Fire. *New York Board of Fire Underwriters*	4	448
New Zealand Earthquake and Fire	4	387
Non-Combustible Scaffolding	2	192
Norwegian Royal Residence Fire. *Norsk Brandvern Forening*	3	302
O		
Oakland Horse Show Fire. *Clarence Heller*	4	444
Office Equipment, Record Protection and. *S. H. Ingberg*	4	410
Oil Burner Ignition	1	21
Oil Fire, Bayonne, N. J.	1	51
Oil Fire, Ripon, Wis.	1	105
Oil Refinery Fire, Brooklyn, N. Y.	3	334
Oil Storage, Municipal Regulation of. *Robert S. Moulton*	3	255
Oklahoma City's Peril. *Editorial.*	1	7
Orange, N. J., Tank Truck Fire. *R. M. Cadman*	4	470
P		
Paint and Lacquer Spraying Fire Record	2	131
Pleasant Valley School Fire, Oklahoma. *C. I. Ingalls*	1	49
Polish National Alliance College Fire	4	436
Portable Cutting and Welding Equipment. *C. W. Mowry*	1	23
Private Fire Brigade Organization. *J. S. Dodge and H. J. Hartmann*	3	296
Providence Inspects Its Homes	3	251
Providence, Rhode Island, State Pier Fire	4	439
R		
Record Protection and Office Equipment	4	410
Rhode Island State Pier Fire, Providence	4	439
Ripon, Wisconsin, Oil Fire	1	105
Rochester Firemen Overcome by Gas	4	467
S		
San Francisco Salt Water Main Failure. *Firemen's Fund Record*	2	138
Scaffolding, Non-Combustible	2	192
Short Extension Courses for Firemen. *Clarence Goldsmith*	3	286
Sprinklered Fires, Loss of Life in	2	218
Sprinklers Shut Off (fire report)	2	144
Sprinkler Tables, Annual	4	476
State Education Building Fire, Harrisburg, Pa.	3	330
State Fire Marshal. *Editorial*	3	239
Stockton, Cal., Eden Square Apartments Fire	4	451
St. Paul, Minn., Anthony Apartments Fire	4	455
S.S. *München* Explosion and Fire. *A. J. Smith*	1	39
Sugar House Fire, Cypremort, La. *H. L. McLean*	3	336
T		
Tank Truck Fire, Orange, N. J. *R. M. Cadman*	4	470
Tannery Fire, Chattanooga, Tenn. *Tennessee Inspection Bureau*	1	44
Theatre Fire Record	1	55
U		
Underground Yard Mains, Locating Leaks in	2	141
V		
Vancouver, Canadian National S.S. Pier Fire. *F. F. Dowling*	2	211
W		
Washington, D. C., Federal Trade Commission Fire	2	123
Water Main Failure, San Francisco. *Firemen's Fund Record*	2	138
Water Supplies in the Drought Regions	4	382